Prior to Use Auto Switches Common Specifications 1

△Specific Product Precautions

Refer to the Auto Switch Precautions on pages 101 to 104 before using auto switches.

Auto Switches Common Specifications

Туре	Reed auto switch	Solid state auto switch	
Leakage current	None	3-wire: 100 μA or less, 2-wire: 0.8 mA or less	
Operating time	1.2 ms 1 ms or less		
Impact resistance	300 m/s ² 1000 m/s ²		
Insulation resistance	$50 \text{ M}\Omega$ or more at 500 VDC Mega (Between lead wire and case)		
Withstand voltage	1500 VAC for 1 minute 1000 VAC for 1 minute (Between lead wire and case) (Between lead wire and case)		
Ambient temperature	−10 to 60°C		
Enclosure	IEC60529 Standard IP67		

Lead Wire

Lead wire length indication (Example)

D-M9BW L

Lead wire length

Nil	0.5 m
M	1 m
L	3 m
Z	5 m

Note 1) Lead wire length Z: 5 m

Applicable auto switches

Solid state auto switch: Manufactured upon receipt of order as standard.

Note 2) 1 m (M): D-M9□(W)(V) only

Note 3) Lead wire length tolerance

Lead wire length	Tolerance
0.5 m	±15 mm
1 m	±30 mm
3 m	±90 mm
5 m	±150 mm




Prior to Use Auto Switches Common Specifications 2

△Specific Product Precautions

Refer to the Auto Switch Precautions on pages 101 to 104 before using auto switches.

Auto Switch Hysteresis

Hysteresis is the distance between the position at which piston movement operates an auto switch to the position at which reverse movement turns the switch off. This hysteresis is included in part of the operating range (one side).



Note) Hysteresis may fluctuate due to the operating environment.

Please contact SMC if hysteresis causes an operational problem.

Contact Protection Box: CD-P11, CD-P12

<Applicable switch models>

D-A7/A8, D-A7 \square H/A80H, D-A73C/A80C, D-C7/C8, D-C73C/C80C, D-E7 \square A, E80A, D-Z7/Z8, D-9/9 \square A, D-A9/A9 \square V, and D-A79W type

The auto switches above do not have a built-in contact protection circuit. A contact protection box is not required for solid state auto switches due to their construction.

- 1) Where the operation load is an inductive load.
- 2 Where the wiring length to load is greater than 5 m.
- 3 Where the load voltage is 100/200 VAC.

Therefore, use a contact protection box with the switch for any of the above cases:

The contact life may be shortened (due to permanent energizing conditions.)

D-A72(H) must be used with the contact protection box regardless of load types and lead wire length since it is greatly affected by loads.

(Where the load voltage is 110 VAC)

When the load voltage is increased by more than 10% to the rating of applicable auto switches (except D-A73C/A80C/C73C/C80C/90/97/A79W) above, use a contact protection box (CD-P11) to reduce the upper limit of the load current by 10% so that it can be set within the range of the load current range, 110 VAC.

Even for the built-in contact protection circuit type (D-A34[A][C], D-A44[A][C], D-A54/A64, D-A59W, D-B59W), use the contact protection box when the wiring length to load is very long (over 30 m) and PLC (Programmable Logic Controller) with a large inrush current is used.

Contact Protection Box Specifications

Part no.	CD-P11		CD-P12
Load voltage	100 VAC or less	200 VAC	24 VDC
Max. load current	25 mA	12.5 mA	50 mA



XL

XL□Q


 $XY \square$

XVD


XGT

CYV

Contact Protection Box Internal Circuit



Contact Protection Box/Dimensions



Contact Protection Box Connection


To connect a switch unit to a contact protection box, connect the lead wire from the side of the contact protection box marked SWITCH to the lead wire coming out of the switch unit. Keep the switch as close as possible to the contact protection box, with a lead wire length of no more than 1 meter.




^{*} Lead wire length — Auto switch connection side 0.5 m


Prior to Use Auto Switches Connection and Example

Basic Wiring




Example of Connection with PLC (Programmable Logic Controller)







Source input specifications 3-wire, PNP



Connect according to the applicable PLC input specifications, as the connection method will vary depending on the PLC input specifications.







Example of AND (Series) and OR (Parallel) Connection

PLC internal circuit


• 3-wire **AND connection for NPN output** (Using relays)



AND connection for NPN output (Performed with auto switches only)



OR connection for NPN output



(Reed auto switch)

Because there is no cur-

rent leakage, the load vol-

tage will not increase

when turned OFF. How-

ever, depending on the

number of auto switches

in the ON state, the indi-

cator lights may some-

times grow dim or not


light up, due to the dispersion and reduction of the

current flowing to the auto

switches.

The indicator lights will light up when both auto switches are turned ON.

• 2-wire 2-wire with 2-switch AND connection




When two auto switches are connected in series, a load may malfunction because the load voltage will decline when in the ON state.

The indicator lights will light up when both of the auto switches are in the ON

Load voltage at ON = Power supply voltage - Residual voltage x 2 pcs. = 24 V - 4 V x 2 pcs.

Example: Power supply is 24 VDC

Internal voltage drop in auto switch is 4 V.



2-wire with 2-switch OR connection (Solid state auto switch) When two auto switches are connected in parallel, malfunction may occur because the load voltage will increase when in the OFF

Load voltage at OFF = Leakage current x 2 pcs. x Load impedance = 1 mA x 2 pcs. x 3 k Ω

Example: Load impedance is $3 \text{ k}\Omega$.

Leakage current from auto switch is 1 mA.



Solid State Auto Switch Direct Mounting Style D-M9N/D-M9P/D-M9B



|XL□

XL_Q XM_ XY_

XVD

XGT

CYV

Grommet

- 2-wire load current is reduced (2.5 to 40 mA).
- Flexibility is 1.5 times greater than the conventional model (SMC comparison).
- Using flexible cable as standard spec




△Caution


Precautions

Fix the auto switch with the existing screw installed on the auto switch body. The auto switch may be damaged if a screw other than the one supplied is used.

Auto Switch Internal Circuit



Auto Switch Specifications



 \sim	Drogran	mmahla	Logio	Controlle

D-M9□ (With indicator light)				
•				
Auto switch model	D-M9N	D-M9P	D-M9B	
Electrical entry direction	In-line	In-line	In-line	
Wiring type	3-w	vire	2-wire	
Output type	NPN	PNP	_	
Applicable load	IC circuit, F	24 VDC relay, PLC		
Power supply voltage	5, 12, 24 VDC	_		
Current consumption	10 mA	10 mA or less		
Load voltage	28 VDC or less	24 VDC (10 to 28 VDC)		
Load current	40 mA	40 mA or less		
Internal voltage drop	0.8 V or less at 10 mA	4 V or less		
Leakage current	100 μA or les	0.8 mA or less		
Indicator light	Red LED illuminates when turned ON.			
Standard	CE marking			

 Lead wires — Oilproof flexible heavy-duty vinyl cord: ø2.7 x 3.2 ellipse, 0.15 mm², 2 cores (D-M9B), 3 cores (D-M9N, D-M9P)

Note 1) Refer to page 96 for solid state auto switch common specifications.

Note 2) Refer to page 96 for lead wire lengths.


Mass (g)


Auto switch model		D-M9N	D-M9P	D-M9B
	0.5	8	8	7
Lead wire length (m)	1	14	14	13
	3	41	41	38
	5	68	68	63

Dimensions

(mm)

D-M9□





Reed Auto Switch Direct Mounting Style D-A90/D-A93/D-A96

((

Grommet




△Caution

Precautions

Fix the auto switch with the existing screw installed on the auto switch body. The auto switch may be damaged if a screw other than the one supplied is used.

Auto Switch Internal Circuit



Note 1) Operating load is an induction load. Note 2) Wiring to the load is 5 m or longer. Note 3) Load voltage is 100 VAC.

Use the contact protection box in any of the above listed situations. The contact point life may decrease. (Refer to page 96 for contact protection box.)

Auto Switch Specifications



Refer to SMC website for the details of the products conforming to the international standards.

PLC: Programmable Logic Controller

D-A90 (Withou	D-A90 (Without indicator light)				
Auto switch model	D-A90				
Applicable load		IC circuit, Relay, PLC			
Load voltage	24 V AC or less	48 V AC or less	100 V AC or less		
Maximum load current	50 mA	40 mA	20 mA		
Contact protection circuit		None			
Internal resistance	1 Ω or les	s (Including lead wire leng	th of 3 m)		
Standard	CE marking				
D-A93, D-A96	(With indicator light)				
Auto switch model	D-A93		D-A96		
Applicable load	Relay, PLC		IC circuit		
Load voltage	24 VDC 100 VAC		4 to 8 VDC		
Load current range and Maximum load current (3)	5 to 40 mA 5 to 20 mA		20 mA		
Contact protection circuit	None				
Internal voltage drop	D-A93: 2.4 V or less (up to 20 mA)/ 3 V or less (up to 40 mA)		0.8 V or less		
Indicator light	Red LED illuminates when turned ON.				
Standard	CE marking				

Lead wires

D-A90/D-A93—Oilproof heavy-duty vinyl cord, ø2.7, 0.18 mm² x 2 cores (Brown, Blue), 0.5 m D-A96—Oilproof heavy-duty vinyl cord, ø2.7, 0.15 mm² x 3 cores (Brown, Black, Blue), 0.5 m Note 1) Refer to page 96 for reed auto switch common specifications.

Note 2) Refer to page 96 for lead wire lengths.

Note 3) Under 5 mA, the strength of the indicator light is poor. In some cases, visibility of the indicator light will not be possible where the output signal is less than 2.5 mA. However, there is no problem in terms of contact output, when an output signal exceeds 1 mA or more.


Mass (9)

Model		D-A90	D-A93	D-A96
Lead wire length	0.5	6	6	8
(m)	3	30	30	41

<u>Dimensions</u>

(mm)

D-A90/D-A93/D-A96





Design / Selection

Marning

1. Confirm the specifications.

Read the specifications carefully and use this product appropriately. The product may be damaged or malfunction if it is used outside the specification range for current load, voltage, temperature or impact.

We do not guarantee against any damage if the product is used outside of the specification range.

2. Cautions for use in an interlock circuit

When an auto switch is used for an interlock signal requiring high reliability, devise a double interlock system to avoid trouble by providing a mechanical protection function, or by also using another switch (sensor) together with the auto switch. Also, perform periodic maintenance and confirm proper operation.

3. Do not make any modifications (including exchanging the printed circuit boards) to the product.

It may cause human injuries and accidents.

⚠ Caution

1. Pay attention to the length of time that a switch is ON at an intermediate stroke position.

When an auto switch is placed at an intermediate position of the stroke and a load is driven at the time the piston passes, the auto switch will operate, but if the speed is too great the operating time will be shortened and the load may not operate properly. The maximum detectable piston speed is:

$$V (mm/s) = \frac{Auto switch operating range (mm)}{Time load applied (ms)} \times 1000$$

In cases of high piston speed, the use of an auto switch (D-F5NTL, F7NTL, G5NTL, M5NTL, M5PTL) with a built-in OFF delay timer (approx. 200 ms) makes it possible to extend the load operating time.

The wide-range detection type D-G5NBL (operating range 35 to 50 mm) may also be useful, depending on the application. Please consult with SMC for other models.

∧ Caution

2. Keep wiring as short as possible.

<Reed>

As the length of the wiring to a load gets longer, the rush current at switching ON becomes greater, and this may shorten the product's life. (The switch will stay ON all the time.)

- 1) Use a contact protection box when the wire length is 5 m or longer.
- 2) Even if an auto switch has a built-in contact protection circuit, when the wiring is more than 30 m long, it is not able to adequately absorb the rush current and its life may be reduced. It is again necessary to connect a contact protection box in order to extend its life. Please consult with SMC in this case.

<Solid state>

3) Although wire length should not affect switch function, use a wire 100 m or shorter.

If the wiring is longer it will likely increase noise although the length is less than 100 m.

When the wire length is long, we recommend the ferrite core is attached to the both ends of the cable to prevent excess noise.

A contact protection box is not necessary for solid state switches due to the nature of this product construction.

Do not use a load that generates surge voltage. If a surge voltage is generated, the discharge occurs at the contact, possibly resulting in the shortening of product life.

If driving a load such as a relay that generates a surge voltage,

<Reed>

Use an auto switch with built-in contact protection circuit or use a contact protection box.

<Solid state>

Use a built-in surge absorbing element type device.

4. Take precautions when multiple cylinders/actuators are used close together.

When multiple auto switch cylinders/actuators are used in close proximity, magnetic field interference may cause the auto switches to malfunction. Maintain a minimum cylinder separation of 40 mm. (When the allowable interval is specified for each cylinder series, use the indicated value.)

The auto switches may malfunction due to the interference from the magnetic fields.

Use of a magnetic screen plate (MU-S025) or commercially available magnetic screen tape can reduce the interference of magnetic force.



XL□

XL□Q XM□



XVD

XGT

CYV

Design / Selection

⚠ Caution

Pay attention to the internal voltage drop of the auto switch.

<Reed>

- Auto switch with an indicator light (Except D-A56, A76H, A96, A96V, C76, E76A, Z76)
 - If auto switches are connected in series as shown below, take note that there will be a large voltage drop because of internal resistance in the light emitting diodes. (Refer to the internal voltage drop in the auto switch specifications.)
 [The voltage drop will be "n" times larger when "n" auto switches are connected.]

Even though an auto switch operates normally, the load may not operate.



In the same way, when operating under a specified voltage, although an auto switch may operate normally, the load may not operate. Therefore, the formula below should be satisfied after confirming the minimum operating voltage of the load.

 $\begin{array}{lll} & \text{Supply} & -\text{Internal voltage} \\ & \text{voltage} & -\text{drop of auto switch} \end{array} > \begin{array}{ll} & \text{Minimum operating} \\ & \text{voltage of load} \end{array}$

 If the internal resistance of a light emitting diode causes a problem, select an auto switch without an indicator light (D-A6□, A80, A80H, A90, A90V, C80, R80, 90, E80A, Z80).

<Solid state/2-wire type>

 Generally, the internal voltage drop will be greater with a 2wire solid state auto switch than with a reed auto switch. Take the same precautions as in 1).

Also, take note that a 12 VDC relay is not applicable.

6. Pay attention to leakage current.

<Solid state/2-wire type>

Current (leakage current) flows to the load to operate the internal circuit even when in the OFF state.

Operating current of load (OFF condition) > Leakage current

If the criteria given in the above formula are not met, it will not reset correctly (stays ON). Use a 3-wire switch if this specification will not be satisfied.

Moreover, leakage current flow to the load will be "n" times larger when "n" auto switches are connected in parallel.

7. Ensure sufficient clearance for maintenance activities.

When designing an application, be certain to allow sufficient clearance for maintenance.

8. When multiple auto switches are required.

"n" indicates the number of auto switches which can be physically mounted on the cylinders/actuators. Detection intervals depends on the auto switch mounting structure and set position, therefore some required interval and set positions may not be available.

9. Limitations of detectable positioning

When using certain mounting brackets, the surface and position where an auto switch can be mounted maybe restricted due to physical interference. For example, when using some bracket types the auto switch cannot be surface mounted at the bottom side of foot bracket, etc.

Select the set position of the auto switch so that it does not interfere with the mounting bracket of the cylinders/actuators (such as trunnion or reinforcement ring).

Use the cylinder and auto switch in proper combination

The auto switch is pre-adjusted to activate properly for an auto-switch-capable SMC cylinder/actuator.

If the auto switch is mounted improperly, used for another brand of cylinders/actuators or used after the alternation of the machine installation, the auto switch may not activate properly.

Mounting / Adjustment

⚠ Caution

1. Do not drop or bump.

Do not drop, bump or apply excessive impacts (300 m/s² or more for reed auto switches and 1000 m/s² or more for solid state auto switches) while handling. Although the body of the auto switch may not be damaged, the inside of the auto switch could be damaged and cause malfunction.

2. Observe the proper tightening torque for mounting an auto switch.

When an auto switch is tightened beyond the range of tightening torque, auto switch mounting screws, auto switch mounting brackets or auto switch may be damaged.

On the other hand, tightening below the range of tightening torque may allow the auto switch to slip out of position.

3. Do not carry a cylinder by the auto switch lead wires.

Never carry a cylinder by its lead wires. This may not only cause broken lead wires, but it may cause internal elements of the auto switch to be damaged by the stress.

4. Fix the auto switch with appropriate screw installed on the switch body. If using other screws, auto switch may be damaged.



Wiring

⚠ Caution

1. Confirm proper insulation of wiring.

Be certain that there is no faulty wiring insulation (contact with other circuits, ground fault, improper insulation between terminals, etc.). Damage may occur due to excess current flow into a switch.

2. Do not wire with power lines or high voltage lines.

Wire separately from power lines or high voltage lines, avoiding parallel wiring or wiring in the same conduit with these lines. Control circuits containing auto switches may malfunction due to noise from these other lines.

3. Avoid repeatedly bending or stretching lead wires.

Broken lead wires will result from repeatedly applying bending stress or stretching force to the lead wires.

Stress and tensile force applied to the connection between the cable and auto switch increases the possibility of disconnection.

Fix the cable in the middle so that it is not movable in the area where it connects with the auto switch.

4. Be certain to connect the load before power is applied.

<2-wire type>

If the power is turned ON when an auto switch is not connected to a load, the auto switch will be instantly damaged because of excess current (short circuit).

It is the same as when the 2-wire brown lead wire (+, output) is directly connected to the (+) power supply terminal.

5. Do not allow short-circuit of loads.

<Reed>

If the power is turned ON with a load in a short circuited condition, the auto switch will be instantly damaged because of excess current flow into the switch.

<Solid state>

All models of D-J51, G5NB and PNP output type auto switches do not have built-in short circuit protection circuits. If a load is short circuited, the auto switch will be instantly damaged as in the case of reed auto switches.

Take special care to avoid reverse wiring with the brown power supply line and the black output line on 3-wire type auto switches.

6. Avoid incorrect wiring.

<Reed>

A 24 VDC auto switch with indicator light has polarity. The brown lead wire or terminal No. 1 is (+), and the blue lead wire or terminal No. 2 is (-).

XL

XL□Q

XM□

 $XY \square$

D-

XVD

XGT

CYV

[For D-97, (+) is on the no-displayed side, (–) is on the black line side.]

1) If connections are reversed, an auto switch will operate, however, the light emitting diode will not light up.

Also, take note that a current greater than that specified will damage a light emitting diode and it will no longer operate. Applicable model:

D-A73, A73H, A73C, C73, C73C, E73A, Z73

D-R73, R73C, 97, 93A, A93, A93V

D-A33, A34, A33A, A34A, A44, A44A

D-A53, A54, B53, B54

When using a 2-color indicator type auto switch (D-A79W, A59W and B59W), the auto switch will constantly remain ON if the connections are reversed.

<Solid state>

- If connections are reversed on a 2-wire type auto switch, the auto switch will not be damaged if protected by a protection circuit, but the auto switch will always stay in an ON state. However, it is still necessary to avoid reversed connections, since the auto switch could be damaged by a load short circuit in this condition.
- 2) If connections are reversed (power supply line + and power supply line -) on a 3-wire type auto switch, the auto switch will be protected by a protection circuit. However, if the power supply line (+) is connected to the blue wire and the power supply line (-) is connected to the black wire, the auto switch will be damaged.
- 7. When the cable sheath is stripped, confirm the stripping direction. The insulator may be split or damaged depending on the direction. (D-M9□ only)





Recommended Tool

Description	Model	
Wire stripper	D-M9N-SWY	

* Stripper for a round cable (ø2.0) can be used for a 2-wire type cable.





Operating Environment

⚠ Warning

1. Never use in an atmosphere of explosive gases.

The structure of auto switches is not intended to prevent explosion. Never use in an atmosphere with an explosive gas since this may cause a serious explosion.

Please contact SMC concerning ATEX compliant products.

⚠ Caution

 Do not use in an area where a magnetic field is generated.

Auto switches will malfunction or magnets inside cylinders/actuators will become demagnetized. (Please consult with SMC if a magnetic field resistant auto switch can be used.)

2. Do not use in an environment where the auto switch will be continually exposed to water.

Although auto switches satisfy IEC standard IP67 construction except some models (D-A3 \square , A44 \square , G39, K39 \square , RNK, RPK) do not use auto switches in applications where continually exposed to water splash or spray. Poor insulation or swelling of the potting resin inside auto switches may cause malfunction.

3. Do not use in an environment with oil or chemicals.

Please consult with SMC if auto switches will be used in an environment with coolant, cleaning solvent, various oils or chemicals. If auto switches are used under these conditions for even a short time, they may be adversely affected by improper insulation, malfunction due to swelling of the potting resin, or hardening of the lead wires.

4. Do not use in an environment with temperature cycles.

Please consult with SMC if auto switches are used where there are temperature cycles other than normal temperature changes, as there may be adverse effects inside the auto switches.

5. Do not use in an environment where there is excessive impact shock.

<Reed>

When excessive impact (300 m/s² or more) is applied to a reed auto switch during operation, the contact point will malfunction and generate or cut off a signal momentarily (1 ms or less). Please consult with SMC if a solid state auto switch can be used according to the environment.

6. Do not use in an area where surges are generated. <Solid state>

When there are units (solenoid type lifter, high frequency induction furnace, motor, radio equipment etc.) which generate a large amount of surge in the area around cylinders/actuators with solid state auto switches, this may cause deterioration or damage to the auto switch's internal circuit elements. Avoid sources of surge generation and disorganized lines.

∧ Caution

7. Avoid accumulation of iron waste or close contact with magnetic substances.

When a large amount of iron waste such as machining chips or spatter is accumulated, or a magnetic substance (something attracted by a magnet) is brought into close proximity with a cylinder with auto switches, or an actuator, it may cause the auto switch to malfunction due to a loss of the magnetic force inside the cylinder/actuator.

- 8. Please contact SMC concerning water resistance, elasticity of lead wires, usage at welding sites, etc.
- 9. Do not use in direct sunlight.
- 10. Do not mount the product in locations where it is exposed to radiant heat.

Maintenance

Marning

 Removal of equipment, and supply/exhaust of compressed air

Before any machinery or equipment is removed, first ensure that the appropriate measures are in place to prevent the fall or erratic movement of driven objects and equipment, then cut off the electric power and reduce the pressure in the system to zero. Only then should you proceed with the removal of any machinery and equipment.

When machinery is restarted, proceed with caution after confirming that appropriate measures are in place to prevent actuators from moving suddenly.

A Caution

- 1. Perform the following maintenance periodically in order to prevent possible danger due to unexpected auto switch malfunction.
 - Secure and tighten auto switch mounting screws.
 If screws become loose or the mounting position is dislocated, retighten them after readjusting the mounting position.
 - Confirm that there is no damage to lead wires.
 To prevent faulty insulation, replace auto switches or repair lead wires, etc., if damage is discovered.
 - Confirm the lighting of the green light on the 2-color indicator type auto switch.
 - Confirm that the green LED is on when stopped at the established position. If the red LED is on, the mounting position is not appropriate. Readjust the mounting position until the green LED lights up.

