# 3 Port Solenoid Valve Series VQ100

## Outstandingly high speed, stable response, and long service life.

ON: 3.5 ms, OFF: 2 ms, Dispension accuracy  $\pm 1$  ms (With light/surge voltage suppressor; supply pressure 0.5 MPa)

200 million cycles or more (Factors determined in a life test by SMC)


## Compact yet provides a large flow capacity

Body width: 9.8 mm C: 0.055 dm³/(s·bar)(Standard, high pressure type) C: 0.14 dm³/(s·bar) (Large flow type)

: Option

## Option

External non-leak Latching Negative COM AC Normally open Vacuum











The fluid contacting section is copper-free and the standard style can be used as it is.


## ■ Wide variations of wiring

#### Manifold



#### **Single Valve Unit**





V100

SY

SYJ VK

VZ

VT

VP

۷G

VP S070

VQ

VKF

٧Z

VS

VFN

## **A** Precautions


Be sure to read before handling. For Safety Instructions and Solenoid Valve Precautions, refer to page 4-18-2.

#### **Manual Override Operation**

## **Marning**


If the manual override is manipulated, since any connected equipment will be activated, make sure to be done only after no danger is confirmed.


#### ■ Non-locking push type (Tool required)



 It is turned ON by pushing the button in the direction indicated by the arrow until it hits the end and is turned OFF by releasing the button.

#### ■ Locking type (Tool required) <Option>






- If the manual override is turned clockwise and the ► mark is adjusted to 1, it will be locked in the ON state.
- If the manual override is turned, counterclockwise and 

  mark is adjusted to 0, locking will be released and the manual override will return.

Note) Ensure the locking type manual override is unlocked before using.

#### ■ Push-locking type (Tool required) <Latching type>





- If the manual override is turned clockwise and the ► mark is adjusted to 1, it will be backed to the reset condition. (Passage P → A)
- If the manual override is turned counterclockwise and the ► mark is adjusted to 0, it will be back to the reset condition. (Passage A → R) (Reset state at the time of shipment.)

[Torque 0.1 N·m or less]


#### **How to Use Plug Connector**

#### **⚠** Caution

#### Attaching and detaching connectors


- To attach a connector, hold the lever and connector unit between your fingers and insert straight onto the pins of the solenoid valve so that the lever's pawl is pushed into the groove and locks.
- To detach a connector, remove the pawl from the groove by pushing the lever downward with your thumb, and pull the connector straight out.

Note) GENTLY pull the lead wire, otherwise it may cause contact failure or disconnection.



#### Crimping of lead wires and sockets

Peel 3.2 to 3.7 mm of the tip of lead wire, enter the core wires neatly into a socket and crimp it with a special crimp tool. Be careful so that the cover of lead wire does not enter into the crimping part. (Crimping tool part no.: DXT170-75-1)




#### Attaching and detaching lead wires with sockets

#### Attaching

Insert the sockets into the square holes of the connector (with A, C, and B indication) and continue to push the sockets all the way in until the lock by hooking into the seats in the connector. (When they are pushed in, their hooks open and they are locked automatically.) Then confirm that they are locked by pulling lightly on the lead wires.

#### Detaching

Pull and detach the lead wire, pressing in on the end of the hook of the socket through the side hole using a stick with thin end (about 1 mm). To reuse the socket, extend the hook outward.



V100

SY

SYJ

VK VZ

-

VP

VG

VP

S070

VQ VKF

VQZ

٧Z

٧S

VFN

4-12-3

## **A** Precautions

Be sure to read before handling. For Safety Instructions and Solenoid Valve Precautions, refer to page 4-18-2.


#### **How to Use Plug Connector**


## **⚠** Caution


#### Wiring specifications

 Lead wires are connected as follows. Connect them to the power supply side.

#### DC positive common








#### How to order connector assembly

#### DC positive common



#### Plug connector lead wire length


The lead wire length of the valve with lead wire is 300 mm. When ordering a valve with a lead wire of 600 mm or longer, be sure to indicate the model number of the valve without connector and connector assembly.


#### Light/Surge Voltage Suppressor

#### **⚠** Caution

For latching type, set energizing side and reset the energizing side are indicated with orange and green respectively.

\* ( ) and the broken line: Large flow type





#### Latching Type

## **⚠** Caution

The latching solenoid is equipped with a self-holding mechanism, which permits a movable iron core in the solenoid to hold the "set" position. Therefore there is no need to energize continuously.

<Special Cautions for Latching Solenoid>

- Make sure ON and OFF signals are not energized simultaneously.
- 2. 10 ms energizing time is necessary for self-holding.
- Please consult with SMC if using in a place with high vibrations (10 G or more) or high magnetic fields.
- 4. Even though this valve is held on to reset position (passage: A → R), it may switch to the set position during transportation or due to impact when mounting valves, etc. Therefore, check the initial position by means of power supply or manual override prior to use.

Latching type	Passage	Indicator light
A-C ON (Set)	$P \rightarrow A$	Orange
B-C ON (Reset)	$A \rightarrow R$	Green

Single	Passage	Indicator light
A-C ON	$P \rightarrow A$	Orange
OFF	$A \rightarrow R$	

V100

SY

SYJ

٧K

٧Z

۷G

۷P

**S070** 

**VKF** 

VQZ

٧Z

VS

**VFN** 

## **A** Precautions

Be sure to read before handling. For Safety Instructions and Solenoid Valve Precautions, refer to page 4-18-2.


#### **How to Use Circular Connector**

(For plug-in manifold: For VV3Q11)


## **⚠** Caution

#### 1. Attaching and detaching connectors

If the manual override is manipulated, since any connected equipment will be activated, make sure to be done only after no danger is confirmed.



#### 2. Wiring specifications



#### Multi-connector pin arrangement

Willi-Com	iectoi	pin arrangeme
1 station	^	SOL. Pin no.
2 stations		SOL. 0 2
3 stations		SOL. 0 3
4 stations	-	SOL. 0 4
5 stations		SOL. 0 5
6 stations		SOL. 0 6
7 stations		SOL. 0 7
8 stations		SOL. 0 8
9 stations		SOL. 9
10 stations	-	SOL. 010
11 stations		SOL. O 11
12 stations		SOL. 0 12
13 stations		SOL. 0 13
14 stations		SOL. 014
15 stations	-	SOL. 0 15
16 stations		SOL. 016
17 stations	-	SOL. 017
18 stations		SOL. 0 18
		СОМ 0 19
		COM 0 20

#### **Terminal No./Lead Wire Color**


Terminal	Lead wire color					
no.	Lead wire color	Dot marking				
1	Black					
2	Brown	_				
3	Red					
4	Orange	_				
5	Yellow	_				
6	Pink	_				
7	Blue	_				
8	Purple	White				
9	Gray	Black				
10	White	Black				
11	White	Red				
12	Yellow	Red				
13	Orange	Red				
14	Yellow	Black				
15	Pink	Black				
16	Blue	White				
17	Purple					
18	Gray					
19	Orange	Black				
20	Red	White				

#### **How to Connect/Disconnect DIN Rail**

## **⚠** Caution

#### Removal


- 1. Loosen the clamp screw of the end plate on both sides.
- 2. Lift the (a) side of the manifold off the DIN rail and slide it in the direction of the (2) side.



#### Mounting

- 1. Hook side (b) of the manifold base on the DIN rail.
- 2. Press down side (a) and mount the end plate on the DIN rail. Tighten the clamp screw on the side.

Proper tightening torque of thread: 0.8 to 1.2 N·m



#### **How to Calculate the Flow Rate**


For obtaining the flow rate, refer to page 4-1-6.

**Electrical wiring specifications** 





#### **How to Order Valves**




## 3 Port Solenoid Valve Series VQ100








#### JIS Symbol



Normally open





#### **Clean Series**

Clean series is available for both standard and option specifications.



**Standard Specifications** 

Item	1		T	ype	Standard type (1 W)	High pressure type (1.5W)	Low wattage type (0.5 W)		
	Valve construction				3 port direct operated poppet (NC)				
	Fluid					Air/Inert gas			
	Maximum o	peratin	g pressu	re	0.7 MPa	0.8 MPa	0.7 MPa		
	Minimum op	perating	pressui	re	(	) MPa (-0.1 MPa <sup>(5)</sup> )	)		
			C[dm <sup>3</sup> /(s	·bar)]	0	.055	0.042		
		1 → 2	b		0	.22	0.27		
	Flow		Cv		0	.014	0.011		
(A)	characteristics		C[dm3/(s	s·bar)]	0	.083	0.045		
Valve specifications		$2 \rightarrow 3$	b		0	.28	0.28		
ifica			Cv		0	0.012			
bec	Response tim	ne (1)			ON: 3.5 m	ON: 3.5 ms, OFF: 2.5 ms			
ve s	Ambient and	fluid te	mperatu	re	–10 to 50°C <sup>(2)</sup>				
Va	Lubrication				Not required				
	Manual overr	ide			Non-locking push type/Locking type (Tool required) <sup>(3)</sup>				
	Mounting orie	entation			Unrestricted				
	Shock/Vibrati	on resi	stance (4	)	150/30 m/s²				
	Enclosure				Dustproof				
	Weight				12.6 g (L/M plug connector, Without sub-plate)				
SU	Coil rated vol	tage		DC	24 V, 12 V				
atio	Allowable voltage fluctuation			±10% of rated voltage					
cific	Coil insulation type			Class B or equivalent					
sbe	Power consumption (Current) DC			1 W (42 mA)	1.5 W (63 mA)	0.5 W (21 mA)			
Electricity specifications	Electrical entry			Grommet  Plug-in, L plug connector, M plug connector  (With light/surge voltage suppressor)					

Note 1) Based on JIS B 8374-1993. With light/surge voltage suppressor (Use clean air), Dispersion accuracy ±1 ms

Note 2) Use dry air to prevent condensation when operating at low temperatures.

Note 3) Locking style: Option

Note 4) Impact resistance: No malfunction occurred when it is tested with a drop tester in the axial direction and at the right angles to the main valve and armature in both energized and de-energized states every once for each condition. (Values at the initial period)

Vibration resistance: No malfunction occurred in a one-sweep test between 45 and 2000 Hz. Test was performed at both energized and de-energized states in the axial direction and at the right angles to the main valve and armature. (Values at the initial period)

Note 5) In vaccum applications, use 10- Clean Series which can use with 3 (R) port vacuum and 1 (P) port vaccum release pressure. (Differential pressure between 3 (P) and 1 (P) is up to the maximum operating pressure for each type.)

V100

SY

SYJ ٧K

٧Z

۷G

**VP** 

**S070** 

VQ **VKF** 

VQZ

٧Z

٧S

**VFN** 

#### **Option**

option									
Type			Latching type AC type		Large flow type	Normally open type			
	Model			VQ110L-□ VQ110-½□		VQ110U-□	VQ120-□		
	Maximum	operati	ng press	ure	0.7 I	МРа	0.6 MPa	0.5 MPa	
S	Ambient a	and fluid	tempera	ature		0 MPa(—10	00 MPa )		
ation			(6) C[dm <sup>3</sup> /(	s·bar)]	0.0	42	0.14	0.04	
ifice	<b></b>	$ \begin{array}{c c} 1 \rightarrow 2 \\ (3 \rightarrow 2) \end{array} $	2 b	)	0.2	7	0.26	0.11	
Valve specifications	Flow charac-		( C		0.0	11	0.036	0.009	
Ive	teristics		(6) C[dm3/(	(s·bar)]	0.0	45	0.14	0.044	
Va		$(2 \rightarrow 3)$	1) b	)	0.2	8	0.25	0.3	
		`	C	V	0.0	12	0.036	0.011	
	Respons	e time	(2)		5 ms or less	15 ms or less	5 ms or less	5 ms or less	
"			24 VI	OC	1 W (42 mA)		0.7 W (29 mA) (3)	1 W (42 mA)	
tions			12 VI	C	1 W (83 mA)		0.7 W (58 mA) (3)	1 W (83 mA)	
ifica	Power			AC	0.6 VA (6 mA)	0.5 VA (5 mA)	_		
bec	consump (Current)		110 V	AC	0.65 VA (5.9 mA)	0.55 VA (5 mA)	l	_	
ity s		200 V	AC	1.2 VA (6 mA)	1.0 VA (5 mA)	_	_		
Electricity specifications					1.3 VA (5.9 mA)	1.1 VA (5 mA)	_		
Ele	Electrical entry (1)				Plug-in, L plug connector, M plug connector (With light/surge voltage suppressor)				



- Note 1) Grommet is available only for normally open type (without light/surge voltage suppressor).

  Normally open type is available only with 1 W DC specifications.

  Note 2) With light/surge voltage suppressor based on JIS B 8374-1993 (clean air).

  Note 3) Inrush: 3.1 W (10 ms after energized.), Holding: 0.7 W


  Note 4) In vacuum applications, use 10- Clean Series which can use with 3 (R) port vacuum and 1 (P) port vacuum release pressure. (Differential pressure between 3 (P) and 1 (P) is up to the
- maximum operating pressure for each type.)

  Note 5) In the case of 1 (P) port vacuum, and 3 (R) port vacuum release, use VQ120 (Normally open type). In this case, 10- is not required.

  Note 6) () values insides denote the air passage for normally open type.

## 3 Port Solenoid Valve Series VQ100

#### Construction



(For N.C. valve)

**Component Parts** 

No.	Description	Material								
1	Solenoid coil	_								
2	Body	Resin								
3	Fixed iron core	Stainless steel								
4	Movable iron core assembly	Stainless steel, Resin								
(5)	Return spring	Stainless steel								
6	Poppet	NBR								
7	Round head combination screw	Carbon steel								
(8)	Interface gasket	NBR								

#### **Replacement Parts**

No.	Description	Material	Part no.
(9)	Sub-plate	ZDC	AXT662-1-1 (1: M5, 2: M3)

Optional parts

• Gasket, screw: VQ100-GS-5



Note) 1 set includes: 1 gasket and 2 screws.
Purchasing order is available in units of 10 pieces.

V100

SY

SYJ

VK VZ

---

VT

VP VG

VP

S070

VQ


VKF VQZ

٧Z


٧S

VFN

#### **How to Order Valves**



#### **Dimensions**







VQZ

## 3 Port Solenoid Valve Series VQ100

#### **Dimensions**




## M plug connector VQ1□0□-□M□-M5 (M3)




( ): M3
 Broken line: Latching, AC and large flow capacity


 One dot chain line: Locking type manual override and push-locking type manual override (latching)



#### **How to Order Manifold Assembly**



#### **How to Order Valves**




**S070** 


VQ

## 3 Port Solenoid Valve Series VQ100

### Plug-in Unit (VV3Q11) Manifold with Multi-connector

The broken line indicates DIN rail mounting style (-D) and side entry connection (S).







#### **Dimensions**

L n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
L1	52	62	72	82	92	102	112	122	132	142	152	162	172	182	192	202	212
L2	63	73	83	93	103	113	123	133	143	153	163	173	183	193	203	213	223
(L3)	83	93	103	113	123	133	143	153	163	173	183	193	203	213	223	233	243
(L4)	112.5	112.5	125	137.5	150	162.5	162.5	175	187.5	200	212.5	212.5	225	237.5	250	262.5	262.5
(L5)	123	123	135.5	148	160.5	173	173	185.5	198	210.5	223	223	235.5	248	260.5	273	273


#### **How to Order Manifold**



#### **How to Order Manifold Assembly**



#### **How to Order Valves**





V100

SY

SYJ

٧K

٧Z

۷T

۷P

۷G

۷P

**S070** 

VQ

**VKF** 

VQZ


٧Z

**VS** 


**VFN** 

## 3 Port Solenoid Valve Series VQ100

#### Plug Lead Unit Manifold (VV3Q12)




## Plug Lead Unit, Type U (Large Flow Type) Mounted Manifold (VV3Q12U)



#### **Manifold Option**

#### **Plug Assembly**



1	Plug	RP13A-12PS-20SC <made by="" co.,="" electric="" hirose="" ltd.=""></made>
2	Female contact	RP19-SC-222 <made by="" co.,="" electric="" hirose="" ltd.=""></made>
3	Vinyl multi-core Cable	VVRF 0.2 mm <sup>2</sup> 20 core


#### **Cable Length**

Part no.	L dimension
VVQ100-12A-1	1.5 m
VVQ100-12A-2	3 m
VVQ100-12A-3	5 m

#### **Blanking Plate Assembly**


#### VVQ100-10A-1

Plug-in unit (VV3Q11) for manifold with multiple connectors



#### VVQ100-10A-2

Plug lead unit (VV3Q12) for manifold




Blanking plate with 2 screws and gasket



#### VV3Q11 for Manifold with Multi-connector


#### <D side end plate assembly>

D side end plate assembly part no.




#### <U side end plate assembly>

U side end plate assembly part no.



#### <DIN rail mounting bracket assembly>

DIN rail mounting bracket assembly part no.






Note) The number of manifold stations cannot be changed.

#### **How to Order Only DIN Rail**

#### DIN rail part no.: AXT100-DR-□

\* Refer to DIN rail dimension table below and put number into  $\square$  to order DIN rail.

Refer to the manifold dimensions on page 4-12-13 to determine L dimension.



<b>L Dimension</b> L = 12.5n + 10.5										
No.	1	2	3	4	5	6	7	8	9	10
L dimension	23	35.5	48	60.5	73	85.5	98	110.5	123	135.5
No.	11	12	13	14	15	16	17	18	19	20
L dimension	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5
No.	21	22	23	24	25	26	27	28	29	30
L dimension	273	285.5	298	310.5	323	335.5	348	360.5	373	385.5
No.	31	32	33	34	35	36	37	38	39	40
L dimension	398	410.5	423	435.5	448	460.5	473	485.5	498	510.5